



C E R T I F I C A T E

Certificate no. 16-SIL-0010036-03-TIC Rev. 01

WE HEREBY CERTIFY THAT

Product description

FULLY WELDED SIDE ENTRY TRUNNION MOUNTED BALL VALVES

Models

SERIES W, W3

Manufacturer

**PIBIVIESSE S.r.l.
Via Bergamina 24 - 20014 Nerviano MI**

IS IN COMPLIANCE WITH THE REQUIREMENTS OF THE STANDARDS

IEC 61508 Parts 1–7:2010

AS RESULT OF THE ASSESSMENT ACCORDING TO THE PROVISION SET OUT IN THE ABOVE-MENTIONED STANDARDS

Summary Report no. **RC-0317-SIL-TIC-PC-0010036-16-06 Rev. 01**

Expiry date **16.03.2020**

Date of first issue **17.03.2017**

Note

This certificate is issued upon the request of the manufacturer as voluntary certification; it does not include the production surveillance.
This certificate does not allow the manufacturer to use the safety mark of TÜV INTERCERT.



Reggio Emilia, 27.10.2017

Eng. Andrea Vivi
TÜV INTERCERT Certification Body

Page 1 of 2

CERTIFICATE ■ CERTIFICATO ■ ZERTIFIKAT ■ SERTIFIKA ■ CERTIFICADO ■ گواهینامه ■ ΠΙΣΤΟΠΟΙΗΤΙΚΟ ■ 証明書 ■ 인증서

CERTIFICATE ■ CERTIFICATO ■ ZERTIFIKAT ■ SERTIFIKA ■ CERTIFICADO ■ گواهینامه ■ ΠΙΣΤΟΠΟΙΗΤΙΚΟ



C E R T I F I C A T E

ANNEX to Certificate no. 16-SIL-0010036-03-TIC Rev. 01

Type	A
HFT	0
Safety functions	<ol style="list-style-type: none"> 1. Close / Open upon the demand of the actuation system 2. Close upon the demand of the actuation system, with inline tightness when in closed position
Mode of operation	Low Demand Mode

Random failure rates				
Configuration	Safety function	λ_{DU} [1/h]	λ_{DD} [1/h]	λ_S [1/h]
Self-relieving - No PST	1	4,13E-08	0,00E+00	0,00E+00
Self-relieving - With PST	1	4,13E-09	3,71E-08	0,00E+00
Self-relieving - No PST	2	5,35E-08	0,00E+00	0,00E+00
Self-relieving - With PST	2	1,60E-08	3,74E-08	0,00E+00
Double piston effect - No PST	1	4,13E-08	0,00E+00	0,00E+00
Double piston effect - With PST	1	4,13E-09	3,71E-08	0,00E+00
Double piston effect - No PST	2	5,32E-08	0,00E+00	0,00E+00
Double piston effect - With PST	2	1,60E-08	3,72E-08	0,00E+00

Systematic capability	3 (Route 1 _S applied)			
Architectural constraints	Route 1 _H :	Applied	Route 2 _H :	Applied
	The product can be used in: <ul style="list-style-type: none"> • single channel configuration: <ul style="list-style-type: none"> ○ up to SIL 2 without external diagnostic tests ○ up to SIL 3 considering external diagnostic tests • double channel configuration: up to SIL 3 			

Remarks:

- Self-relieving configuration: both upstream and downstream seats shall be of self-relieving type (i.e. single barrier in the flow direction)
- Double piston effect configuration: at least downstream seat shall be of double piston effect type (i.e. double barrier in the flow direction)
- For further details, including environmental conditions, limitations of use, lifetime, failure rates traceability, mean repair times, common cause factors and systematic capability constraints, make reference to Safety Manual SM-SIL-FW.

END OF CERTIFICATE

Reggio Emilia, 27.10.2017


 Eng. Andrea Vivi
 TÜV INTERCERT Certification Body

CERTIFICATE ■ CERTIFICATO ■ ZERTIFIKAT ■ SERTIFIKA ■ CERTIFICADO ■ گواهینامه ■ ΠΙΣΤΟΠΟΙΗΤΙΚΟ ■ 証明書 ■ 證明 ■ شهادة